

University of the Philippines Manila
The Health Sciences Center
BIDS & AWARDS COMMITTEE I (BAC I)

Proj. Ref. No. : BAC1-20-033 **Opening of Bid:**
End-User : PROPERTY AND SUPPLY DIVISION & OTHERS
Project : SUPPLY & DELIVERY OF MEDICAL LIQUID OXYGEN
Contract : CY2021

ITEM NO.	QUANTITY	UNIT	ITEM DESCRIPTION	ABC PER UNIT (PhP)	QUOTATIONS (all taxes included)	
					in figures	in words
1	1,175,000	cu.m	Medical Liquid Oxygen, minimum purity of 99.5%	13.18		
TOTAL APPROVED BUDGET FOR THE CONTRACT: PhP15,486,500.00						

TERMS & CONDITIONS:

- The supplier undertakes to supply the hospital its total requirements of liquid oxygen for the period of one (1) year. The supplier must be a manufacturer of liquid oxygen not merely a distributor or retailer. (Submit certification signed by the President or Board secretary)
- The Supplier must supply to the hospital its liquid oxygen with a minimum purity of 99.5% or based on the standard purity set-up by the Products Standards Agency. A copy of latest laboratory results as regards purity shall be submitted upon dropping of bid under envelop no.1 and for every delivery
- The supplier must install at the hospital, one (1) unit liquid oxygen cryogenic tank at 6,000 gallons capacity, with vaporizer accessories and the connecting pipeline systems, capable of maintaining the hospital's one (1) week consumption at any given time. The said installation of Vacuum Insulated Enclosure (VIE) must be free of charge (labor and materials) and the hospital will provide the space for the supplier's specification.
- The supplier shall dismantle its storage tank if they fail for two (2) consecutive periods to participate in the bids to supply liquid oxygen to PGH.
- The supplier also agrees to provide labor without any additional cost to the hospital in the quarterly preventive maintenance of the above mentioned VIE during the contract period
- In case the Vacuum Insulated Enclosure malfunctions, the hospital shall notify the supplier immediately in writing or through telephone after malfunctioning was noticed or become apparent. Such malfunctioning shall be given immediate and direct attention by the supplier.
- The supplier shall undertake to deliver to the hospital its liquid oxygen supply level at any given time
- Price of liquid oxygen shall be fixed for one (1) year
- The supplier shall deliver the liquid oxygen in bulk quantity, the volume of which is determined by means of a metering device called "flow meter" installed at the delivery tank with assurance of a zero leakage on the transfer hose and fittings.
- The hospital shall give the supplier a right of way for unloading the products any time during regular office hours (Monday to Friday) for 8:00 am to 4:30 pm. The supplier shall be allowed to enter the hospital premises only upon presentation and proper screening of legitimate credentials for the purpose of delivery, inspection test, maintenance, repairs, replacement, removal of suppliers equipment or for any other legitimate purpose subject to the approval by the hospital.
- The supplier will be charged for the actual electrical consumption.
- In case of flow meter malfunction and leakages were observe during the unloading of liquid oxygen, liquid level gauge will be the basis for determining the quantity/volume delivered.
- Free Safety Orientation/Training on storage , use, and handling, etc. must be provided by the winning bidder/s.

Approved by:

Dean LEONARDO R. ESTACIO, JR, PhD
Chairperson

(Signature over Printed Name of President/Gen. Manager)

(Name & Address of Company)