

"PHIC-Accredited Health Care Provider"
ISO 9001 Certified

Date: November 15, 2023
Purchase Request No.: PUR23-11-1034
Mode of Procurement: EMERGENCY CASES (53.2)

General Conditions:

- For further information, you may call at (02) 8554-8400 local [3024] and look for Ms. Maria Agnes Lumbis

JULIET E. MADIZ
Acting Head, Purchasing Office

End-User: OETS

End-User: OETS								
Item No.	Item Description	Qty	UOM	Unit Price (PHP)	Quoted Unit Price	Statement of Compliance		Remarks (Brand and Specifications)
						Yes	No	
1	Replacement of One (1) unit, 2000 Amperes Air Circuit Breaker (ABC) compatible to existing unit xxxxxxxxxxxxxxxxxxxxxxxxxxxxxx	1	unit	671,456.68				
Approved Budget for the Contract				671,456.68				
Total Amount of Quotation (in Words & in Figures)								

I/We, the undersigned Supplier, hereby OFFER to supply/deliver/perform the above described items.

Name of Company: _____
 Name of Representative: _____
 Position / Designation: _____
 Signature: _____



PHILIPPINE GENERAL HOSPITAL
The National University Hospital
University of the Philippines Manila
PURCHASING OFFICE
Taft Avenue, Manila

PHIC-Accredited Health Care Provider
ISO 9001 Certified

TERMS AND CONDITIONS:

1. Bidders shall provide correct and accurate information required in this form.
2. Price quotation/s, to be denominated in Philippine peso shall include all taxes, duties and/or levies payable.
3. Quotations exceeding the Approved Budget for the Contract shall be rejected.
4. Award of contract shall be made to the lowest quotation (for goods and infrastructure) or, the highest rated offer (for consulting services) which complies with the minimum technical specifications and other terms and conditions stated herein.
5. Any interlineations, erasures or overwriting shall be valid only if they are signed or initialed by you or any of your authorized representative/s.
6. The item/s shall be delivered according to the requirements specified in the Technical Specifications.
7. The UPM-PGH shall have the right to inspect and/or test the goods to confirm their conformity to the technical specifications.
8. The UPM-PGH shall assume no responsibility whatsoever to compensate or indemnify any supplier for expenses incurred in the preparation of Quotations/Proposals.
9. In case of two or more bidders are determined and declared as Lowest Calculated and Responsive Quotation, the UPM-PGH shall adopt and employ "draw lots" as the tie-breaking method to finally determine the winning provider in accordance with GPPB Circular 06-2005.
10. If the Awardee fails to effect delivery with the prescribed period, the UPM-PGH may upon its discretion, extend delivery period of subject, however, to the imposition of appropriate liquidated damages, the amount of which shall be at least equal to one-tenth of one percent (0.01%) of the cost of the unperformed portion for every day of delay, collectible from any money due or maybe due to the supplier/contractor. Once the cumulative amount of liquidated damages reaches ten percent (10%) of the amount of the contract, the UPM-PGH may rescind or terminate the contract, without prejudice to other courses of action and remedies open to it. If the Awardee, however, fails to effect completed delivery within the extended period, the UPM-PGH shall have the right to cancel said contract and shall constitute a ground for disqualification of the Awardee from future biddings, without prejudice to the imposition of other sanctions provided for under 2016 Revised IRR.
11. The UPM-PGH reserves the rights to reject any or all bids or not award the contract, to waive any formality or defect therein and to accept any or all offers that may be considered most advantageous to the Government.
12. Compliance with Republic Act (R.A.) 9184 and other applicable laws.

UNDERTAKING

I/We undertake, if our quotation/proposal is accepted, to deliver the items in accordance with the General /Terms and Conditions contained in the Request for Quotation/Proposal.

Name of Company: _____

Address: _____

Name of Representative: _____

Position / Designation: _____

Signature _____

Office Tel. No.: _____

Fax / Mobile No.: _____

e-Mail Address: _____

Date: _____

NOV 10 2023



IR-01-11042023

Subject: Power Outage at LCB Wing Ground, 4th to 7th Floor

Background:

Around 0800H of November 4, 2023, a power outage affecting Left Central Block Wing 4th floor to 7th floor reported to us.

Action Taken:

- SDX Team immediately proceed to Powerhouse to investigate the power outage.
 - SDX Team together with OETS Team investigate the power outage.
 - SDX Team together with OETS Team conducted tracing and isolation of circuit breakers to restore the power supply gradually.
 - SDX Team temporarily transferred the load of floors from Distribution Circuit Breaker to Emergency Panels to support the hospital operation needs to some affected areas.
- NOTE: Attached is the summary of the areas that were transferred from Normal Power to Emergency Power:




Initial Finding/s:

- Air Circuit Breaker: MDP-C serving 4th to 7th floor LCB Wing at Powerhouse suddenly tripped off.
- Air Circuit Breaker is set to 42% (500A) from its full capacity of 1200A. Temporarily adjusted to 83% (1000A) of its capacity.
- Air Circuit Breaker is old and out of support, may cause major breakdown of equipment due to its faulty tripping mechanism.

Recommendations:


- For replacement of Faulty Air Circuit Breaker 2000A and scheduled Preventive Maintenance of the Electrical System at Powerhouse

Human Factors / Behaviours:


-  Possible people-related;
-  Not Equipment-related; Equipment is been operational over long time without preventive maintenance.
-  Possible people-related; Updated load schedule of the Hospital. For preventive maintenance of sub-station and seek professional advise for revamp of sub-station.

Prepared by:

11-10-23


Engr. Revie Marcial
Sodexo, Project Manager

Noted By:


Engr. Benedick Balilu
Sodexo, Contract Manager



Equipment



Process

Prevent – Protect – Preserve
Take Time Out for Safety